

	Title: YALE OFFICE OF FACILITIES PROCEDURE MANUAL Chapter: 01 - Yale Design Standard Division: 09 00 00 Finishes	Section: 09 51 00 Requirements for Acoustic Ceilings
		Date: December 2023
		Author: Office of Facilities

PART 1 - INTRODUCTION

1.1 PURPOSE

This section contains general design criteria for acoustical ceilings.

PART 2 - GENERAL DESIGN REQUIREMENTS

2.1 SUMMARY

Yale School of Medicine

A. GRID/TILE:

1. At Corridors, Offices, Conference Rooms & Labs: Armstrong Ultima tegular fine texture 2x2 high recycled content (1911 HRC) with 15”/16” grid.
2. General: No concealed spline systems are to be used, anywhere.
3. At Wet Locations: Preferred tile – Armstrong #605 Travertine Ceramaguard.

Date	Description of Change	Pages / Sections Modified	ID
12/12/23	Template update	-	Office of Facilities