

	Title: YALE OFFICE OF FACILITIES PROCEDURE MANUAL Chapter: 01 - Yale Design Standard Division: 09 00 00 Finishes	Section: 09 67 00 Requirements for Wall Finishes
		Date: December 2023
		Author: Office of Facilities

PART 1 - INTRODUCTION

1.1 PURPOSE

This section contains general design criteria for wall finishes.

PART 2 - GENERAL DESIGN REQUIREMENTS

2.1 SUMMARY

Yale School of Medicine

A. Materials

Linoleum Sheet Wainscoting

Provide Forbo Marmoleum Linoleum Sheet Flooring manufactured by Forbo in color selected by architect from the range currently available from Forbo 78" wide x 105 feet long, having a nominal total thickness of 0.080in. (2.0mm). The wear surface shall consist of a homogeneous mixture of linoleum cement (linseed oil, natural tree resins, drying oil catalysts), wood flour, cork flour, color pigments and filler calendared onto a jute fabric backing. Colors and pattern detail shall be dispersed throughout the thickness of the wear layer.

Date	Description of Change	Pages / Sections Modified	ID
12/12/23	Template update	-	Office of Facilities