

## 09650

### Resilient Flooring

This document provides design standards only, and is not intended for use, in whole or in part, as a specification. Do not copy this information verbatim in specifications or in notes on drawings. Refer questions and comments regarding the content and use of this document to the Yale University Project Manager.

### **CONTENTS**

A. Summary

# A. Summary

This section contains general design criteria for resilient flooring.

#### Yale School of Medicine

#### **Materials**

#### **RUBBER TILE**

Manufacturer: Nora Rubber Flooring

Product: Norament 925 Grano

Color: 1238 Basalt

#### COMPOSITION TILE

12" x 12" (VCT is no longer to be used at YSM unless approved by PM for special situations such as matching an existing condition)

Manufacturer: American Biltrite

Product: Estrie Pattern: Viera

Neutral field colors and accents:

Light (white): ALL-615 Cotton Tails

Medium (light gray): ALL-603 Granite Falls Dark (dark gray): ALL-633 Polished Pewter

Accent colors:

At discretion of the designer, from entire Viera color collection. Color(s) and pattern(s) to be reviewed and approved for each project.

## Yale University DesignStandards



Please note: for future flexibility (bench reconfiguration/removal), composition tile in laboratories shall not be laid out using bench locations to frame floor patterns, rather the lab flooring shall be all neutral field colors with color accents only near the perimeter of the space or shall be a continuous, undifferentiated pattern unrelated to bench locations. In addition, composition tile shall be continuous under all casework.

#### FILLED VINYL SHEET:

Limited to specific programmatic space, such as cold rooms and operating rooms; to be approved by Project Manager.

#### **EXTRA STOCK:**

No specific attic stock is desired or required. Storing extra materials is at the discretion of the Facilities Project manager.

#### Floor Finish

Floors must be completely stripped, including all corners and edges, to remove all existing finish and soil before the new finish is applied

Recommended stripping technique and equipment are as follows: Spread stripper with a designated stripper mop and let solution dwell 3 to 5 minutes. Do not let the stripper dry. For large unrestricted areas, use a 20" diameter, corded scrubbing machine with a 3M system Black pad (or equivalent). For tight spots, use a 3M system Doodle Bug (or equivalent) and a scraper. Pick-up the slurry using a wet vacuum. After slurry pick-up, rinse the floor twice with a clean rinse mop using clean, clear water. Do not mix clean mop and stripper mop.

Four (4) coats of new floor finish will be applied as follows: Floor finish shall be applied with a new, synthetic finish mop, using SC Johnson, Time Saver. Apply Two (2) medium coats of floor finish, allowing sufficient drying time between coats (per manufacturer's recommendations). Wait 1-2 hours. Burnish the floor area using an ultra-high speed burnishing machine. Apply Two (2) more medium coats of finish, allowing sufficient drying time between coats.